

REPORT RECEIVED BY DESE ON OCTOBER 3, 2024

NOTICE OF TEST RESULTS

Facility: Missouri School for the Blind

Date Results Received: September 30, 2024

Summary of Results:

- Type of Result: Preliminary
- Number of Outlets with results at or above 5ppb: 15
 - See enclosed email from vendor

Implemented Remediation Efforts:

- The drinking water outlet will be turned off.

OA-FMDC Next Steps:

- Planned Remediation Efforts
 - Replace hardware at this drinking water outlet.
 - Install filter on drinking water outlet.
- Testing Plan
 - This outlet and other drinking water outlets identified on the final test results will be tested again after the hardware is replaced and a filter is installed.

Requirements of Statute:

- DESE must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DESE shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
 - The above written test results and explanation;
 - A description of the previously implemented and planned remediation efforts; and
 - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DESE shall submit annual testing results to DHSS. *Id.*

REPORT RECEIVED BY DESE ON OCTOBER 3, 2024

From: [Jenn Tapuaiga](#)
To: [Otto, Kayla](#); [Bruemmer, Julie](#); [Klaus, Jessica](#)
Cc: [Nick Kiser](#); [Walt Giesing](#)
Subject: RE: Advanced Notifications - Lead Testing - Missouri School for the Blind
Date: Monday, September 30, 2024 12:35:30 PM
Attachments: [image001.png](#)

Hello ,

Lead was detected in some of the samples that are currently being tested.
Please see [preliminary results](#) of those samples below.

SO#_53679 - MOSCBD

Sample ID	LEAD	Level Detected
07-1305-2 FD	0.011 mg/L	11 ppb
07-1305-1 FD	0.007 mg/L	7 ppb
RR Annex Sink 1 07-1319-2 FD	0.007 mg/L	7 ppb
Annex DF Elevator Lobby DF2 FD	0.005 mg/L	5 ppb
Annex 2nd Floor Kitchen FD	0.008 mg/L	8 ppb
Sink 2 East Hall Womens RR FD	0.012 mg/L	12 ppb
103 E2 FL	0.005 mg/L	5 ppb
K2 FD	0.008 mg/L	8 ppb
B Dorm RR Sink 4 FD	0.005 mg/L	5 ppb
CR 105 RR FD	0.006 mg/L	6 ppb
CR 107 SW FD	0.005 mg/L	5 ppb
CR 105 FD	0.005 mg/L	5 ppb
3E Dorm Small RR SE Corner Sink 1 FD	0.013 mg/L	13 ppb
3E Dorm Main RR Sink 1 FD	0.005 mg/L	5 ppb
100 C-1 FD	0.014 mg/L	14 ppb

We wanted to make sure you had this information as soon as possible.

Official results will be sent to you once they are completed.

Please let us know if you have any questions.

Thanks,

Jenn Tapuaiga
Quality Control & Lab Manager / Buyer
Walter Louis Fluid Technologies
530 South 5th Street
Quincy, IL 62301
Office: 217-223-2017

REPORT RECEIVED BY DESE ON OCTOBER 3, 2024

Cell: 217-242-5153

Fax: 217-223-7734

www.walterlouis.com



Creating Total Water Solutions Since 1968

This e-mail, including attachments, may include confidential and/or proprietary information, and may be used only by the person or entity to which it is addressed. If the reader of this e-mail is not the intended recipient or his or her authorized agent, the reader is hereby notified that any dissemination, distribution, or copying of this e-mail is prohibited. If you have received this e-mail in error, please notify the sender by replying to this message and delete this e-mail immediately.