

NOTICE OF TEST RESULTS

Facility: Missouri School for the Blind

Date Results Received: December 16 and 22, 2025

Summary of Results:

- Type of Result: Preliminary and Final Results
- Number of Outlets with results at or above 5ppb: 3
 - See enclosed email from vendor

Implemented Remediation Efforts:

- Place permanent not potable water signs above the hand washing stations.

OA-FMDC Next Steps:

- Testing Plan
 - All fixtures are considered clear due to the three failed fixtures being hand washing stations.
 - Testing will be completed in five years.

Requirements of Statute:

- DESE must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DESE shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
 - The above written test results and explanation;
 - A description of the previously implemented and planned remediation efforts; and
 - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DESE shall submit annual testing results to DHSS. *Id.*

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
44	MO School for the Blind – St. Louis, MO	3815 Magnolia Ave St. Louis, MO 63110	SO# 54654 B	
1	SAMPLE LOCATION	2 FD 104 NW Faucet	0.008 mg/L	8 ppb
2	SAMPLE LOCATION	2 FL 104 NW - 4196044	-----	ND
3	SAMPLE LOCATION	54 FD B Dorm Kitchen Faucet	-----	ND
4	SAMPLE LOCATION	54 FL B Dorm Kitchen Faucet	-----	ND
5	SAMPLE LOCATION	60 FD Life Dorm Restroom	-----	ND
6	SAMPLE LOCATION	60 FL Life Dorm Restroom	-----	ND
7	SAMPLE LOCATION	#75 FD E Wing Hallway by Stairwell Water Fountain Bottle Filler	-----	ND
8	SAMPLE LOCATION	75 FL E Wing Hallway by Stairwell Water Fountain Bottle Filler	-----	ND
9	SAMPLE LOCATION	76 FD Restroom by Room 200 SE	-----	ND
10	SAMPLE LOCATION	#76 FL Restroom by Room 200 SE	-----	ND
11	SAMPLE LOCATION	#80 FD D Dorm Restroom	-----	ND
12	SAMPLE LOCATION	80 FL D Dorm Restroom	-----	ND
13	SAMPLE LOCATION	#81 FD D Dorm Restroom	-----	ND
14	SAMPLE LOCATION	81 FL D Dorm Restroom	-----	ND
15	SAMPLE LOCATION	#85 FD E Dorm Faucet	0.001 mg/L	1 ppb
16	SAMPLE LOCATION	#85 FL E Dorm Faucet	-----	ND
17	SAMPLE LOCATION	#86 FD E Dorm Faucet	-----	ND
18	SAMPLE LOCATION	86 FL E Dorm Faucet	-----	ND
19	SAMPLE LOCATION	#87 FD E Dorm Faucet	0.002 mg/L	2 ppb
20	SAMPLE LOCATION	87 FL E Dorm Faucet	0.003 mg/L	3 ppb

FD = First Draw

FL = Flush

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
44	MO School for the Blind – St. Louis, MO	3815 Magnolia Ave St. Louis, MO 63110	SO# 54654 B	
21	SAMPLE LOCATION	88 FD Annex 2nd Floor Breakroom Faucet	0.005 mg/L	5 ppb
22	SAMPLE LOCATION	88 FL Annex 2nd Floor Restroom	-----	ND
23	SAMPLE LOCATION	89 FD Annex 2nd Floor Restroom	0.038 mg/L	38 ppb
24	SAMPLE LOCATION	89 FL Annex 2nd Floor Restroom	0.002 mg/L	2 ppb
25	SAMPLE LOCATION	92 FD Annex Men's Restroom 07-1305	-----	ND
26	SAMPLE LOCATION	92 FL Annex Men's Restroom 07-1305	-----	ND
27	SAMPLE LOCATION	93 FD Annex Men's Restroom 07-1305	-----	ND
28	SAMPLE LOCATION	93 FL Annex Men's Restroom 07-1305	-----	ND
29	SAMPLE LOCATION	97 FD Annex Women's Restroom 07-1308	0.001 mg/L	1 ppb
30	SAMPLE LOCATION	97 FL Annex Women's Restroom 07-1308	-----	ND
31	SAMPLE LOCATION	98 FD Annex Men's Restroom 07-1319-2	-----	ND
32	SAMPLE LOCATION	98 FL Annex Men's Restroom 07-1319-2	-----	ND
33	SAMPLE LOCATION	99 FD Annex Men's Restroom 07-1319-2	0.001 mg/L	1 ppb
34	SAMPLE LOCATION	99 FL Annex Men's Restroom 07-1319-2	-----	ND
35	SAMPLE LOCATION	100 FD Annex Women's Restroom 07-1318-2	0.001 mg/L	1 ppb
36	SAMPLE LOCATION	100 FL Annex Women's Restroom 07-1318-2	-----	ND

FD = First Draw

FL = Flush

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
44	MO School for the Blind – St. Louis, MO	3815 Magnolia Ave St. Louis, MO 63110	SO# 54654 B	
37	SAMPLE LOCATION	104 FD W Wing Boys Locker Room	-----	ND
38	SAMPLE LOCATION	#104 FL W Wing Boys Locker Room	-----	ND
39	SAMPLE LOCATION	#105 FD W Wing Area Restroom	-----	ND
40	SAMPLE LOCATION	105 FL W Wing Area Restroom	-----	ND
41	SAMPLE LOCATION	108 FD E Wing Boys Locker Room	-----	ND
42	SAMPLE LOCATION	#108 FL E Wing Boys Locker Room	-----	ND
43	SAMPLE LOCATION	#109 FD E Wing Boys Locker Room Water Fountain Bubbler	-----	ND
44	SAMPLE LOCATION	109 FL E Wing Boys Locker Room Water Fountain Bubbler	-----	ND

FD = First Draw

FL = Flush

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488477****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #2 FD 104 NW 4195879(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.008	1	11/25/2025 09:32		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488477

Lead Only

Date Printed: 12/17/2025 12:17:17 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488478****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #2FL 104 NW 4196068(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:34		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488479****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #54FD
 B
 Dorm Kitchen Faucet 4195971(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:38		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488480****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #54FL B Dorm Kitchen Faucet 4196104(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:40		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488481****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #60FD Life Dorm Restroom 4195895(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 08:53		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488482****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #60FL Life Dorm Restroom 4196101(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 08:55		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488483****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #75FD E Wing Hallway by Stairwell Bottle Fill
 4195892(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:26		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488484****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #75FL E Wing Hallway by Stairwell
 4196103(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:28		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488485****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #76FD Restroom by Room 200SE
 4195960(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:18		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488485

Lead Only

Date Printed: 12/17/2025 12:17:21 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488486****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #76FL Restroom by Room 200SE
 4196090(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:20		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488487****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #80FD
 Dorm Restroom 4195890(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:49		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488488****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #80FL D Dorm Restroom 4196105(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:51		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488489****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #81 FD D Dorm Restroom 4195894(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:52		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488490****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #81FL D Dorm Restroom 4196096(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:54		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488490

Lead Only

Date Printed: 12/17/2025 12:17:24 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488491****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #85FD E Dorm Faucet 4195873(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	11/25/2025 09:03		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488492****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #85FL E Drom Faucet 4196087(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:05		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488493****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #86FD E Dorm Faucet 4195882(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:07		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488493

Lead Only

Date Printed: 12/17/2025 12:17:25 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488494****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #86FL E Dorm Faucet 4196067(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 09:09		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488495****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #87FD E Dorm Faucet 4195883(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	11/25/2025 09:11		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488496****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #87FL E Dorm Faucet 4196093(SO#-54654-
 MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.003	1	11/25/2025 09:13		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488497****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #88FD Annex Second Floor Breakroom(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.005	1	11/25/2025 11:01		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488498****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #88FL Annex Second Floor Breakroom(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 11:03		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488499****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #89FD Annex Second Floor Restroom
 11252501(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.038*	1	11/25/2025 11:05		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488500****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #89FL Annex Second Floor Restroom
 11252502(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	11/25/2025 11:07		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488500

Lead Only

Date Printed: 12/17/2025 12:17:29 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488501****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #92FD Annex Mens Restroom 07-1305
 4195896(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:44		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488502****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #92FL Annex Mens Restroom 07-1305
 41960(SO#-54654-MOSCBD)99
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:46		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488503****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #93FD Annex Mens Restroom 07-1305
 4195911(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:48		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488504****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #93FL Annex Mens Restroom 07-1305
 4196080(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:50		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488505****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #97FD Annex Womens Restroom 07-1308
 4195901(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	11/25/2025 10:36		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488505

Lead Only

Date Printed: 12/17/2025 12:17:32 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488506****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #97FL Annex Womens Restroom 07-1308
 4196095(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:36		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488507****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #98FD Annex Mens Restroom 07-1319-2
 4195888(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:28		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488507

Lead Only

Date Printed: 12/17/2025 12:17:33 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488508****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #98FL Annex Mens Restroom 07-1319-2
 4196077(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:30		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488509****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #99FD Annex Mens Restroom 07-1319-2
 4195868(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	11/25/2025 10:32		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488509

Lead Only

Date Printed: 12/17/2025 12:17:34 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488510****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #99FL Annex Mens Restroom 07-1319-2
 4196092(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:34		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488511****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #100FD Annex Womens Restroom 07-1318-2
 4195889(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:00**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	11/25/2025 10:52		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488511

Lead Only

Date Printed: 12/17/2025 12:17:35 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488512****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #100FL Annex Womens Restroom 07-1318-2
 4196074(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:54		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488512

Lead Only

Date Printed: 12/17/2025 12:17:36 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488513****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #104FD W Wing Boys Locker Room
 4195866(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:05		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488514****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #104FL W Wing Boys Locker Room
 4196070(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:07		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488515****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #105FD West Wing Area Restroom
 4195899(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:00		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488516****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #105FL West Wing Area Restroom
 4196075(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:02**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:02		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488517****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #108FD E Wing Boys Locker Room
 4195906(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:18		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488517

Lead Only

Date Printed: 12/17/2025 12:17:39 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488518****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #108FL E Wing Boys Locker Room
 4196094(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:20		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488519****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #109FD E Wing Boys Locker Room Bubbler
 4195891(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:12		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Page 1 of 1 488519

Lead Only

Date Printed: 12/17/2025 12:17:40 PM

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 488520****12/17/2025**

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy , IL 62301-4808

Source: #109FL E Wing Boys Locker Room Bubbler
 4196079(SO#-54654-MOSCBD)
Source City: St. Louis
Source State: MO

Date/Time Received: 12/1/2025 09:38**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	11/25/2025 10:14		12/10/2025

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.